



UNIVERSAL ENGINEERING SCIENCES
4475 S.W. 35TH TERRACE, GAINESVILLE, FL. 32608
(352) 372-3392 FAX NO:(352) 336-7914

DATE: April 15, 2016

Certificate of Authorization No. 549

MOISTURE-DENSITY RELATIONSHIP TEST
ASTM-1557

CLIENT O'Steen Bros.
0
0
0


PROJECT: Pit Check
0.00
0.00
0.00

DATE TESTED: 9/30/2015

DATE SAMPLED: 9/29/2015

SAMPLE LOCATION: O'Steen Archer Pit

SOIL DESCRIPTION: Tan Sand



OPT MOISTURE: **15.3**
MAX DENSITY: **105.4**